


CAMBRIDGE HOUSING AUTHORITY



C A M B R I D G E
M A S S A C H U S E T T S
02139
(617) 864-3020

February 9, 1982

Mr. Robert W. Healy
City Manager
City of Cambridge
Cambridge, MA 02139

RE: City Council Order No. 2
dated January 11, 1982

Dear Mr. Healy:

This is intended to serve as an updating you requested regarding Councillor Danehy's above-mentioned Order regarding one of the incinerators at Jefferson Park.

Although there remains some doubt regarding the cause of the fire on Rindge Avenue, the CHA has taken the following preventive measures:


1. The manager has replaced all of the spark arrestors throughout the development to insure that no ash escapes the chimney. (It should be noted that accessibility to the roofs at Jefferson Park is an on-going problem and vandalism of spark arrestors does occur on a sporadic basis.)
2. We now conduct daily inspections of the roofs to insure that all spark arrestors are in satisfactory condition.
3. Finally, the incinerators at Jefferson Park Extension will no longer be used once the redevelopment of that complex is completed.

Sincerely,

Daniel J. Wenschel
Executive Director

DJW/mbh

RECEIVED
FEB 12 8 52 AM '82
OFFICE OF THE
CITY MANAGER



CITY OF CAMBRIDGE

CAMBRIDGE, MASSACHUSETTS 02139

Tel. 498-9011

EXECUTIVE DEPARTMENT

ROBERT W. HEALY

City Manager

February 22, 1982

To the Honorable, the City Council:

With reference to City Council Order No. 2 of January 11, 1982, regarding the incinerator at Jefferson Park, I transmit herewith communication from Daniel J. Wuenschel, Executive Director of the Cambridge Housing Authority.

Very truly yours,

Robert W. Healy
City Manager

RWH/b

S-86
Agenda Item Number Thirteen

Re: response to Order # 2 of January 11,
1982 relative to the incinerator at Jeffer-
son Park.

In City Council,

February 22, 1982

2/22/82
Placed on File