



CITY OF CAMBRIDGE
DEPARTMENT OF PUBLIC WORKS
COUNCIL ORDER CORRESPONDENCE

TO: ROBERT HEALY, CITY MANAGER

FROM: WILLIAM SOMMERS, COMMISSIONER, DPW

DATE: 10/6/89

SUBJECT: COUNCIL ORDER #(S): 4

DATE: 9/25/89

COUNCILLOR: Russell

DESCRIPTION OF PROBLEM: Roof leak at Gatley Shelter

DEPARTMENT ANSWER: Investigation of the roof showed multiple penetrations in the scupper near the area of leakage. Scupper holes were repaired, and the area will be monitored during future rain storms to determine the effectiveness of repairs. Roof professionals will be contacted if the repairs prove ineffective.

CC: CHRONOLOGICAL FILE
TICKLER FILE
COUNCIL ORDER FILE
DIVISION HEAD
Richard Rossi

RECEIVED

89 OCT 10 AM 9:54

OFFICE OF THE CITY MANAGER



CITY OF CAMBRIDGE

CAMBRIDGE, MASSACHUSETTS 02139

TEL. 498-9011

EXECUTIVE DEPARTMENT

ROBERT W. HEALY
City Manager


RICHARD C. ROSSI
Deputy City Manager

October 16, 1989

To the Honorable, the City Council:

In response to Awaiting Report Item No. 64, regarding the inspection of the roof at the Gately Shelter, please find attached a report from William Sommers, Commissioner of Public Works.

Very truly yours,



Robert W. Healy
City Manager

RWH/dls
enclosure (1)

Agenda # 11

S-688

Response to Awaiting Report Item # 64 re:
to the inspection of the roof at the
Gately Shelter.

In City Council,

Oct. 16, 1989

Placed on file