



CITY OF CAMBRIDGE
CAMBRIDGE, MASSACHUSETTS 02139

TEL. 349-4300
FAX. 349-4307



3

EXECUTIVE DEPARTMENT
ROBERT W. HEALY
City Manager

RICHARD C. ROSSI
Deputy City Manager

September 28, 1998

To The Honorable, The City Council:


In response to Awaiting Report Item No. 24, regarding a report on the status of the frequently unoperational elevators at 30 Churchill Avenue, Executive Director of the Cambridge Housing Authority Daniel J. Wuenschel reports the following:

On two occasions this summer in the late afternoon of June 13th and July 23rd, torrential downpours caused water from the storm drains to back up into the elevator pit. This put the elevator out of service.

In both instances, the elevator company was on the scene immediately and working overtime had the elevator back in operation by early the next morning.

Mr. Wuenschel instructed his staff to work with the elevator company to see if a solution can be found for the problem. Other than those two occasions, the elevator at 30 Churchill Avenue has been in operation except for routine maintenance.

Very truly yours,



Robert W. Healy
City Manager

RWH/mec



CITY OF CAMBRIDGE
CAMBRIDGE, MASSACHUSETTS 02139

TEL. 349-4300
FAX. 349-4307



3.

EXECUTIVE DEPARTMENT
ROBERT W. HEALY
City Manager

RICHARD C. ROSSI
Deputy City Manager

September 14, 1998

To The Honorable, The City Council:

In response to Awaiting Report Item No. 29, regarding a report on the status of the frequently unoperational elevators at 30 Churchill Avenue, Executive Director of the Cambridge Housing Authority Daniel J. Wuenschel reports the following:

On two occasions this summer in the late afternoon of June 13th and July 23rd, torrential downpours caused water from the storm drains to back up into the elevator pit. This put the elevator out of service.

In both instances, the elevator company was on the scene immediately and working overtime had the elevator back in operation by early the next morning.

Mr. Wuenschel instructed his staff to work with the elevator company to see if a solution can be found for the problem. Other than those two occasions, the elevator at 30 Churchill Avenue has been in operation except for routine maintenance.

Very truly yours,

Robert W. Healy
City Manager

RWH/mec

Consent Agenda #3

529 S

Relative to a report on the status
of the frequently unoperational
elevators at 30 Churchill Avenue.

In City Council September 14, 1998

xb Action Taken.

SEP. 28 1998

PLACED ON FILE