



CITY OF CAMBRIDGE

MASSACHUSETTS

WATER DEPARTMENT
250 FRESH POND PARKWAY
CAMBRIDGE, MASS. 02138

John J. Cusack, Jr.
Superintendent

617-498-9070

TO: Robert W. Healy, City Manager
FROM: *JJC* John J. Cusack, Jr., Superintendent
DATE: March 2, 1989
SUBJECT: COUNCIL ORDER #13 - (02/13/89)
WATER LEAK @ CORNER OF TROWBRIDGE ST. & BROADWAY

In response to the February 13th Council Order on the subject referenced above, please be advised that the Water Department has reviewed this item and is submitting the following report.

The leak at 438 Broadway was on a 1-inch lead-lined service connection installed in 1927. This leak was reported on February 9th, at which time the Water Department contacted the property owner, who agreed to place an order for a 1-inch copper tubing service renewal. The Water Department commenced work on the renewal on February 14th to control the leakage, and subsequently returned to this locatin on February 22nd to complete the renewal.


This renewal project was complicated by the conditions that the existing service line was connected to the 30-inch water transmission main in Broadway and part of the service line was located under concrete stairs entering the front of 438 Broadway.

JJC/mp

OFFICE OF THE CITY MANAGER

89 FEB 31 PM 11:20

RECEIVED



CITY OF CAMBRIDGE

CAMBRIDGE, MASSACHUSETTS 02139

TEL. 498-9011

EXECUTIVE DEPARTMENT

ROBERT W. HEALY

City Manager

RICHARD C. ROSSI

Deputy City Manager

March 6, 1989

To the Honorable, the City Council:

In response to City Council Order No. 13 of February 13, 1989 regarding a water leak at the corner of Trowbridge and Broadway, I submit the attached report from the Water Department.

Very truly yours,

Robert W. Healy
City Manager

Agenda Item No. 4 *S-148*

Re: water leak at the corners of Trowbridge
St. & Broadway.

In City Council,

March 6, 1989

3-6-89

Placed on file