



CITY OF CAMBRIDGE
INTEROFFICE CORRESPONDENCE

To : James L. Sullivan
City Manager

Date : November 7, 1979

From : Conrad C. Fagone, Commissioner
Public Works Department *C. Fagone* **Reference**

Subject : City Council Order #9 - 10-29-79 - Councillor Crane
Heating System at High School

The heating system at the High School Complex is working and the "bugs" are being worked out. The heating plant is a very complex system. Some problems that are corrected or being worked on are:

1. Incinerator stack smoke was circulated through vents twice, problem appears to be corrected.
2. Some rooms were over cooling - system is being balanced.
3. Small boiler needs to run reheat coils and hot water. School Department needed clarification and additional instruction.
4. Manuals as presented are too complex, contractor furnished simplified manuals.
5. City representatives on project are continuing to monitor technical controls and will correct any problems.

RECEIVED

Nov 8 11 16 AM '79

OFFICE OF THE
CITY MANAGER



CITY OF CAMBRIDGE

CAMBRIDGE, MASSACHUSETTS 02139
Tel. 498-9011


EXECUTIVE DEPARTMENT
JAMES L. SULLIVAN
City Manager

November 19, 1979

To the Honorable, the City Council:

With respect to Awaiting Report Item No. 31 regarding the heating system in the High School, attached is a report from Conrad C. Fagone, Commissioner of Public Works.

Very truly yours,



James L. Sullivan
City Manager

JLS/mbf
Enc.

Agenda #9

5-6/9

Response to Awaiting Report no. 31 re:
heating system in the High School.

In City Council,

November 19, 1979

11/19/79

-Placed on File-