



City of Cambridge

IN CITY COUNCIL

January 26, 1976

ORDERED:

That, in accordance with the provisions of an ordinance relative to placing and maintaining signs, the Commissioner of Public Works be and hereby is authorized to grant a permit to Dim Sum House Restaurant for the erection of a sign at 36 Boylston Street


Provided that, before erecting the above named sign, the petitioner shall obtain a permit from the Building Department and file with the City Clerk a satisfactory bond in the sum of Four Thousand Dollars (\$4,000) conditioned to save harmless the City of Cambridge from all claims for damages arising from the construction, maintenance and use of said sign.

In City Council January 26, 1976.
Adopted by the affirmative vote of 7 members.
Attest:- Paul E. Healy, City Clerk.

A true copy,

ATTEST:-

A handwritten signature in cursive script, reading "Paul E. Healy".



RECEIVED BY
OFFICE OF CITY CLERK

Cambridge,

12/18

1975

JAN 21 3 49 PM '76

To the Honorable, the City Council
of the City of Cambridge.

The undersigned respectfully prays

that Dim Sum House be granted permit to erect a sign of the
following specifications in front of premises 36 BOYLSTON ST.

Type: ELECTRIC STEEL-PLASTIC
(State whether Electric or otherwise and material used in construction)

Reading matter to go on sign: Dim Sum House Restaurant.

SIGN TO BE FASTENED TO ANGLEIRON 2"x2"x1/4" CLIPS, SECURED
TO BUILDING WITH 1/2"x4" LAGS & SHIELDS

Size: 6' x 30"

Weight: 200 lbs

How Erected: A: 6' B: AT LEAST 10'
(A: Give exact distance sign is to extend from building over sidewalk.
B: Also exact distance from bottom of sign to sidewalk.)

x Ether Lai
(Signature of Applicant)

x 36 Boylston St. Cambridge,
(Address)
Mass.

NOTICE - REGULATIONS

SEC. 3608. BUILDING CODE. . PROJECTING SIGNS

1. A projecting sign shall be constructed wholly of incombustible materials, with a metal frame and supports; shall not project out from the wall of a building or other structure a horizontal distance of more than 6 feet; and shall be secured in a rigid manner.

2. Any part of such a sign shall not be less than 10 feet, nor more than 45 feet, above the grade beneath the sign.

approved J. J. Conway 1-26-76

6. H-9

PETITION

of Dim Sum House Restaurant

for sign

No. 36 Boylston St.

Jan. 26 19: 76

In City Council, Jan. 26 19:76

Referred to the Committee on

Attest:

City Clerk.

ll
/A