



CITY OF CAMBRIDGE
CAMBRIDGE, MASSACHUSETTS 02139

TEL. 349-4300
FAX. 349-4307

EXECUTIVE DEPARTMENT
ROBERT W. HEALY
City Manager

RICHARD C. ROSSI
Deputy City Manager

June 10, 1996

To The Honorable, The City Council:

In response to Awaiting Report Item No. 28, regarding an inspection of the bleachers on the Huron Avenue side of Glacken Field, Public Works Commissioner Ralph Dunphy reports the following:

Public Works staff has inspected the bleachers at Glacken Field. In order to correct the height of the step, Public Works will add another step to the bottom of the bleachers. This adjustment was completed the week of June 3rd.

Very truly yours,

Robert W. Healy
City Manager

RWH/mec

Consent Agenda #2

S-314

Relative to Awaiting Report Item
Number Twenty-eight, regarding
an inspection of the bleachers
on the Huron Avenue side of
Glacken Field.

In City Council June 10, 1996

Placed on file