

City of Cambridge PUBLIC NOTICE

To all owners of buildings containing six (6) or more dwelling units: The Cambridge City Council on September 15, 1980 accepted Section 26C of Chapter 148 of the General Laws, which reads as follows:

Section 26C

In any city or town which accepts this section, apartment houses containing six (6) or more dwelling units, hotels, boarding or lodging houses, or family hotels which are not regulated by sections twenty-six A and twenty-six B shall be equipped with an automatic smoke or heat detector in each dwelling unit and each hallway floor.

The head of the Fire Department as defines in section one shall enforce the provisions of this section.

Therefore, all owners concerned will take immediate action to be in compliance with this law prior to December 31, 1981.

Guidelines for existing buildings available from the Fire Prevention Bureau at 876-0125 extension 65.

Owners of units urged to confer with their licensed electrician to complete their installation.

Per order of the Fire Chief
Daniel J. Reagan, Fire Chief.

*Herald - Oct 9, 1980
Thursday - Camb.
Page Edition*

City of Cambridge

PUBLIC NOTICE

To all owners of buildings containing six (6) or more dwelling units: The Cambridge City Council on September 15, 1980 accepted Section 26C of Chapter 148 of the General Laws, which reads as follows:

Section 26C

In any city or town which accepts this section, apartment houses containing six (6) or more dwelling units, hotels, boarding or lodging houses, or family hotels which are not regulated by sections twenty-six A and twenty-six B shall be equipped with an automatic smoke or heat detector in each dwelling unit and each hallway floor.

The head of the Fire Department as defines in section one shall enforce the provisions of this section.

Therefore, all owners concerned will take immediate action to be in compliance with this law prior to December 31, 1981.

Guidelines for existing buildings available from the Fire Prevention Bureau at 876-0125 extension 65.

Owners of units urged to confer with their licensed electrician to complete their installation.

Per order of the Fire Chief
Daniel J. Reagan, Fire Chief

*Herald - Oct 9, 1980
Thursday - Camb.
Page Edition*

City of Cambridge

PUBLIC NOTICE

To all owners of buildings containing six (6) or more dwelling units: The Cambridge City Council on September 15, 1980 accepted Section 26C of Chapter 148 of the General Laws, which reads as follows:

Section 26C

In any city or town which accepts this section, apartment houses containing six (6) or more dwelling units, hotels, boarding or lodging houses, or family hotels which are not regulated by sections twenty-six A and twenty-six B shall be equipped with an automatic smoke or heat detector in each dwelling unit and each hallway floor.

The head of the Fire Department as defines in section one shall enforce the provisions of this section.

Therefore, all owners concerned will take immediate action to be in compliance with this law prior to December 31, 1981.

Guidelines for existing buildings available from the Fire Prevention Bureau at 876-0125 extension 65.

Owners of units urged to confer with their licensed electrician to complete their installation.

Per order of the Fire Chief
Daniel J. Reagan, Fire Chief

*Herald - Oct 9, 1980
Thursday - Camb.
Page Edition*

City of Cambridge

PUBLIC NOTICE

To all owners of buildings containing six (6) or more dwelling units: The Cambridge City Council on September 15, 1980 accepted Section 26C of Chapter 148 of the General Laws, which reads as follows:

Section 26C

In any city or town which accepts this section, apartment houses containing six (6) or more dwelling units, hotels, boarding or lodging houses, or family hotels which are not regulated by sections twenty-six A and twenty-six B shall be equipped with an automatic smoke or heat detector in each dwelling unit and each hallway floor.

The head of the Fire Department as defines in section one shall enforce the provisions of this section.

Therefore, all owners concerned will take immediate action to be in compliance with this law prior to December 31, 1981.

Guidelines for existing buildings available from the Fire Prevention Bureau at 876-0125 extension 65.

Owners of units urged to confer with their licensed electrician to complete their installation.

Per order of the Fire Chief
Daniel J. Reagan, Fire Chief.

*Herald - Oct 9, 1980
Thursday - Camb.
Page Edition*

City of Cambridge

PUBLIC NOTICE

To all owners of buildings containing six (6) or more dwelling units: The Cambridge City Council on September 15, 1980 accepted Section 26C of Chapter 148 of the General Laws, which reads as follows:

Section 26C

In any city or town which accepts this section, apartment houses containing six (6) or more dwelling units, hotels, boarding or lodging houses, or family hotels which are not regulated by sections twenty-six A and twenty-six B shall be equipped with an automatic smoke or heat detector in each dwelling unit and each hallway floor.

The head of the Fire Department as defines in section one shall enforce the provisions of this section.

Therefore, all owners concerned will take immediate action to be in compliance with this law prior to December 31, 1981.

Guidelines for existing buildings available from the Fire Prevention Bureau at 876-0125 extension 65.

Owners of units urged to confer with their licensed electrician to complete their installation.

Per order of the Fire Chief
Daniel J. Reagan, Fire Chief.

*Herald - Oct. 9, 1980
Thursday - Camb.
Page. Edition*



City of Cambridge

CALENDAR ITEM NO. 6

AMENDED ORDER

IN CITY COUNCIL

September 15, 1980

COUNCILLOR D. SULLIVAN

ORDERED:

That the City of Cambridge accept the provisions of Chapter 148, Section 26C of the Massachusetts General Laws, concerning installation of approved smoke detectors in residential buildings.

In City Council September 15, 1980.

Adopted as amended by the affirmative vote of 9 members.

Attest:- Paul E. Healy, City Clerk.

A true copy;

ATTEST:

A handwritten signature in cursive script, reading "Paul E. Healy". The signature is written in dark ink and is positioned to the right of the word "ATTEST:".



CITY OF CAMBRIDGE

CITY HALL, CAMBRIDGE, MASSACHUSETTS 02139 • (617) 498-9017

OFFICE OF
THE CITY CLERK

September 9, 1980

Mr. Charles Sprague
Superintendent of Buildings
City Hall
Cambridge, MA 02139

Dear Mr. Sprague:

Enclosed you will find an order submitted by Councillor David Sullivan on the installation of smoke detectors in residential buildings.

Please be advised that the City Council will be holding a hearing on this matter on September 15, 1980 at 6:30 P. M. in the City Council Chamber, City Hall, Cambridge, Massachusetts.

The City Council has requested that you be present at this hearing.

Your kind attention in this matter will be greatly appreciated.

Very truly yours,

A handwritten signature in cursive script, reading "Paul E. Healy", is written over a horizontal line.

Paul E. Healy, City Clerk.

PEH/dl

Enc. (1)



CITY OF CAMBRIDGE

CITY HALL, CAMBRIDGE, MASSACHUSETTS 02139 • (617) 498-9017

OFFICE OF
THE CITY CLERK

September 9, 1980

Mr. Daniel J. Reagan
Fire Chief
Fire Department
491 Broadway
Cambridge, MA 02139

Dear Chief Reagan:

Enclosed you will find an order submitted by Councillor David Sullivan on the installation of smoke detectors in residential buildings.

Please be advised that the City Council will be holding a hearing on this matter on September 15, 1980 at 6:30 P. M. in the City Council Chamber, City Hall, Cambridge, Massachusetts.

The City Council has requested that you be present at this hearing.

Your kind attention in this matter will be greatly appreciated.

Very truly yours,

Paul E. Healy, City Clerk.

PEH/dl

Enc. (1)



City of Cambridge

COUNCILLOR D. SULLIVAN

4.
IN CITY COUNCIL
August 4, 1980

ORDERED:

That the City of Cambridge accept the provisions of Chapter 148, Section 26E of the Massachusetts General Laws, concerning installation of approved smoke detectors in residential buildings.



City of Cambridge

COUNCILLOR D. SULLIVAN

4.
IN CITY COUNCIL
August 4, 1980

ORDERED:

26C
That the City of Cambridge accept the provisions of Chapter 148, Section ~~26A~~ of the Massachusetts General Laws, concerning installation of approved smoke detectors in residential buildings.

Order # 4

S-418

C. D. Sullivan re: concerning the installation of approved smoke detectors in residential buildings.

copy of order sent to Fire and Building Depts 9/16/80 (all)
Cincinnati # 8 Sept 8/80

Fire Chief & Supt of Buildings notified 9/9/80 (all)

- 9/15/80 - Adopted -
AS amended adopted -

In City Council,

WITH
SECTION August 4, 1980
5 August 4, 1980

Tabled on Motion

of L. David Sullivan

Sept 8, 1980

Hearing set for Sept 15/80
AT 6:30 PM

Notice Fire, Bldg -
to appear