



CITY OF CAMBRIDGE

CAMBRIDGE, MASSACHUSETTS 02139
Tel. #98-9011

EXECUTIVE DEPARTMENT
ROBERT W. HEALY
City Manager

March 11, 1985

To the Honorable, the City Council:

With reference to Awaiting Report Item No. 39,
City Council Order No. 25 of February 25th, I have
been notified by the Water Department that the water
leak in front of 9 Granite Street has been repaired.
The source of the leak was a circumferential break on
a 6-inch distribution main installed in 1901.

Very truly yours,

Robert W. Healy
City Manager

RWH/b

Agenda Item No. 6

S-194

Re: response to Awaiting Report Item No. 39
on the repair of a water leak in front of the
premises numbered 9 Granite Street.

In City Council,

March 11, 1985

3/11/85

*- Placed
on
File.*