



CITY OF CAMBRIDGE
INTEROFFICE CORRESPONDENCE

To James L. Sullivan - City Manager

Date July 10, 1980

From William H. Crocker - City Electrician


Reference *WHC*

Subject City Council Order No. 5 of June 16, 1980

Re: Lighting at Clarendon and Massachusetts Avenue Park

Clarendon Street, Massachusetts Avenue Park has four 175 watt mercury-vapor sterneer fixtures. This will, in my opinion supply marginal lighting for this area.

As you know I do not consider the sterneer fixture an efficient source of light. Reference to this is the Cambridge Common. If inadequate lighting results in a problem at Clarendon Street Park, one alternative is a flood light on the utility pole on Clarendon Street for general flood lighting. This might distract from the aesthetics of the park.



CITY OF CAMBRIDGE

CAMBRIDGE, MASSACHUSETTS 02139
Tel. 498-9011

EXECUTIVE DEPARTMENT

JAMES L. SULLIVAN


City Manager

August 4, 1980

To the Honorable, the City Council:

With respect to City Council Order No. 5 of June 16, 1980,
relative to lighting at the Clarendon Street and Massachusetts
Avenue park, enclosed please find copy of a report from William
H. Crocker, City Electrician.

Very truly yours,



James L. Sullivan
City Manager

JLS/mbf
Enc.

Agenda # 8

5-379

Response to City Council Order Number 5
of June 16, 1980 relative to lighting at the
Clarendon Street and Massachusetts Avenue
park.

In City Council,

August 4, 1980

Placed on file