



City of Cambridge

IN CITY COUNCIL

September 9, 1974

ORDERED:

That, in accordance with the provisions of an ordinance relative to placing and maintaining signs, the Commissioner of Public Works be and hereby is authorized to grant a permit to Anchor Fuel Company for the erection of a sign at 27 Western Avenue, Cambridge.

Provided that, before erecting the above named sign, the petitioner shall obtain a permit from the Building Department and file with the City Clerk a satisfactory bond in the sum of Three Thousand Dollars (\$3,000) conditioned to save harmless the City of Cambridge from all claims for damages arising from the construction, maintenance and use of said sign.

In City Council September 9, 1974.


Adopted by the affirmative vote of 8 members.

Attest:- Paul E. Healy, City Clerk.

A true copy,

ATTEST:-

Paul E. Healy
CITY CLERK



*Proposed Illuminated Sign
To Be Erected For Anchor Fuel Co.
at 27 Western Ave.*

RECEIVED BY
OFFICE OF CITY CLERK

Cambridge, August 28 19 74

To the Honorable, the City Council
of the City of Cambridge:
CAMBRIDGE, MASS.

The undersigned respectfully prays

that they be granted permit to erect a sign of the

following specifications in front of premises 27 Western Ave.

Type: Metal & Plastic Illuminated Sign
(State whether Electric or otherwise and material used in construction)

Reading matter to go on sign: Anchor

Size: 8' x 4'

Weight: 192 lbs.

How Erected: A: 6' B: 10'6"

(A: Give exact distance sign is to extend from building over sidewalk.
B: Also exact distance from bottom of sign to sidewalk.)

Anchor Fuel Company

(Signature of Applicant)

167 Pleasant St., Marblehead, Mass.

(Address)

NOTICE - REGULATIONS

SEC. 3608. BUILDING CODE. . PROJECTING SIGNS

1. A projecting sign shall be constructed wholly of incombustible materials, with a metal frame and supports; shall not project out from the wall of a building or other structure a horizontal distance of more than 6 feet; and shall be secured in a rigid manner.

2. Any part of such a sign shall not be less than 10 feet, nor more than 45 feet, above the grade beneath the sign.

Approved J Conway 8-29-74

47.

149

PETITION

of Anchor Fuel Company

for sign

No. 27 Western Avenue

Sept. 9, 1974 19:

In City Council, 19:

Referred to the Committee on

Attest:

CR
A

City Clerk.