



CITY OF CAMBRIDGE
INTEROFFICE CORRESPONDENCE

To Robert W. Healy
City Manager

Date July 28, 1989

From Joseph J. Cellucci *JJC*
Building Commissioner
Subject Councillor Walsh Order 2-13-89

Reference


SUBJECT: Inspectional Services verification of the most recent date, prior to the February 11th malfunction, of inspection & certification of the emergency generator at 55 Essex Street & of every Senior Citizen Apartment Complex.

Upon receipt of the above captioned request, I instructed Michael Nicoloro, Senior Wiring Inspector to meet with the Housing Authority Electrician in order to inspect and institute a program for continued testing of generators located in all Housing Authority buildings.

Inspector Nicoloro reports that all units have been tested and presently are in good working order.

A weekly test of all units is being conducted by the Housing Authority Electrician and the results of the test are entered into a log.

RECEIVED
89 JUL 28 PM 4:07
OFFICE OF THE CITY MANAGER



CITY OF CAMBRIDGE

CAMBRIDGE, MASSACHUSETTS 02139
TEL. 498-9011

EXECUTIVE DEPARTMENT
ROBERT W. HEALY
City Manager

RICHARD C. ROSSI
Deputy City Manager

August 7, 1989

To the Honorable, the City Council:

In response to Awaiting Report No. 23 regarding inspection and certification of emergency generators at senior housing complexes, I submit the attached report from the Inspectional Services Department.

Very truly yours,

Robert W. Healy
City Manager

Re: response to Awaiting Report Item 23 on
inspection & certification of emergency
generators at senior housing complexes.

In City Council,

August 7, 1989

Placed in file