

**CITY OF CAMBRIDGE
MASSACHUSETTS**

**WATER DEPARTMENT
250 FRESH POND PARKWAY
CAMBRIDGE, MA 02138**

RECEIVED
95 JUN 19 PM 2:50
OFFICE OF THE CITY MANAGER

**617-349-4770
Fax: 617-349-4796**

**Michael A. Nicoloro, P.E.
Managing Director**


**SUBJECT: RESPONSE TO CONSENT ORDER # 8 DATED 6/12/95 -
 DOES HYDRANT @ E.T. SULLIVAN ROAD WORK?**
DATE: JUNE 12, 1995
FROM: MIKE NICOLORO
TO: ROBERT HEALY, CITY MANAGER

In accordance with previous and recent results from on-going tests conducted by the Cambridge Fire & Water Departments, the hydrant located on E.T. Sullivan Road does not provide an adequate flow rate for firefighting activities. This inadequate flow rate is attributed to the age and tuberculated condition of the water mains in the general area of Sullivan Rd. . This situation has existed in this area for many years. Capital funds have been appropriated in the FY 96 budget to make improvements to the water mains in this area that will in turn, improve the water flow from the hydrant in question as well as other hydrants within the area of concern. Improvements to water quality could be a secondary benefit that may be derived from this work. The CWD will be meeting with the Fire Department to finalize the plans for the water main improvements over the next several weeks. Our goal is to start the work this calendar year. With regard to this issue, water main improvements are scheduled for the following streets:

- * Lawn St.
- * May St.
- * Sullivan Rd.
- * St. Saviour St.
- * Thingville St.
- * Vineyard St.
- * Belmont St.

Please advise if you require further information or assistance with this matter.
Thank You.

c r.rossi
file: a:\cwg\healyros\hydsul
date: 6/12/95



CITY OF CAMBRIDGE

CAMBRIDGE, MASSACHUSETTS 02139

TEL 349-4300

FAX 349-4307

EXECUTIVE DEPARTMENT
ROBERT W. HEALY
City Manager

RICHARD C. ROSSI
Deputy City Manager

June 26, 1995

To The Honorable, The City Council:

Please find attached a response to Awaiting Report Item No. 50, regarding the hydrant on Edward T. Sullivan Road, received from Michael Nicoloro, Managing Director of the Water Department.

Very truly yours,

Robert W. Healy
City Manager

RWH/mec
attachment

Consent Agenda # 2

Response to Awaiting Report Item Number
Fifty regarding the hydrant on Edward T.
Sullivan Road.

S-223

See Order # 8 of 6/12/95.
for original order.

In City Council,

June 26, 1995

Placed in file