

Harvey	Mr	No plan
Clifton	"	No plan
Charles	"	No plan
Futts	"	No plan
Donnell	"	Plan in file. Line - some encroachments on both sides. Grade - very irregular, partly above and partly below grade.
Upton	"	Similar to Hamp. St. Plan in file, Line - encroachments on E. side 0 to 0.54' Grade - center from 0 to 0.60' low
Pilgrims	"	Plan on file. Line - no encroachments of magnitude. Grade - very low 3.00 in places.
Brendon	"	Plan on file. Line - no encroachments. Grade - has filled to correct grade.
Peaberton	"	Plan on file. Line - encroachments on E. side 0 to .44'. Grade and material poor - 8" to 12" good material needed.
Fairfield	"	Plan in file. Line - no encroachments of magnitude. Grade and material poor - 8" to 12" good material needed.
Wright	"	No plan

52

Repat,

35

City Engineer
in regard to certain streets
desired to be accepted by
petitioners therefor.